



NOTES:

1. PRE-CAST REINFORCED CONCRETE RISER RINGS SHALL COMPLY WITH ASTM C-39 AND ASTM C-478.
2. ALL JOINTS BETWEEN PRE-CAST ELEMENTS, ADJUSTING RINGS AND MANHOLE FRAMES SHALL BE SET IN PLACE WITH A BUTYL RUBBER JOINT SEALANT.
3. USE EAST JORDAN NO. 7220-M1 FOR FRAME & GRATE OR APPROVED EQUAL IN CURB LINE INLETS & MANHOLES.
4. USE EAST JORDAN NO. 6527 GRATE OR APPROVED EQUAL FOR ALL INLETS IN NON-PAVED LOCATIONS.
5. SUMP PUMP JUNCTION BOXES SHALL BE 30" DEEP AND SHALL HAVE AN EAST JORDAN NO. 1020 FRAME WITH TYPE A SOLID LID OR APPROVED EQUAL SET TO FINISHED GRADE. LID CASTING SHALL HAVE THE WORDS "CITY OF BATAVIA", "STORM" PER CITY DETAIL.
6. PRECAST CONCRETE RINGS 8-INCH MAXIMUM WITH BITUMASTIC BED FOR EACH RING MAY BE USED.



**CITY OF BATAVIA
PUBLIC WORKS DEPARTMENT**

**SHEET: 1 OF 1
DATE: 6/8/22**

INLET TYPE A

STANDARD NO. 4.01